

Number	89388/02	Replaces	89388/01
Issued	27-09-2016	Scope	2009/142/EC (30-11-2009)
Report number	150300781/3	Contract number	E 6520
PIN	0063CQ3781		

## EC TYPE EXAMINATION CERTIFICATE (GAD)

Kiwa hereby declares that the Condensing Boilers, types

**Remeha Quinta Ace 160,**

**Remeha Gas 220 Ace 160,**

**Remeha Gas 220 Ace 200,**

**Remeha Gas 220 Ace 250,**

**Remeha Gas 220 Ace 300**

manufactured by

**Remeha B.V.**

**Apeldoorn, The Netherlands**

meet the essential requirements as described in the


Directive 2009/142/EC relating to appliances burning gaseous fuels.

Appliance types : B23, B23P, B33\*, C13, C33, C43, C53, C63, C83, C93  
 Appliance categories : I2L, I2H, I2E, I2EK, I2ELL, I2E+, I2Esi, I2E(R), I2E(S),  
 I2ELw, I2HS, I3P, I3B/P, II2L3P, II2L3B/P, II2H3P,  
 II2H3B/P, II2ELL3B/P

)\* only for Remeha Quinta Ace 160

**Countries:**

Algeria	Denmark	Israel	Morocco	Spain
Armenia	Egypt	Italy	Netherlands, the	Sweden
Australia	Estonia	Jordan	New Zealand	Switzerland
Austria	Finland	Kazakhstan	Norway	Syria
Azerbaijan	France	Kyrgyzstan	Palestine	Tajikistan
Belarus	Georgia	Latvia	Poland	Tunisia
Belgium	Germany	Lebanon	Portugal	Turkey
Bulgaria	Greece	Liechtenstein	Romania	Turkmenistan
Chile	Hungary	Lithuania	Russia	Ukraine
China	Iceland	Luxembourg	Saudi Arabia	Un. Arab Emirates
Croatia	Iran	Malta	Serbia	Un. Kingdom
Cyprus	Iraq	Moldova	Slovakia	Uzbekistan
Czech Republic	Ireland	Montenegro	Slovenia	

  
 Luc Leroy  
 Kiwa

**kiwa**  
 Approved

EC Directive



2009/142/EC

G A S T E C

**CE**

**0063**

Certificate

**MARKETBAU-REMEHA KFT.**

2040 Budaörs, Gyár u. 2.  
Tel: 23/503-980 Fax: 23/503-981  
E-mail: remeha@remeha.hu  
Web: www.remeha.hu

**TELJESÍTMÉNY NYILATKOZAT**

**Nyilatkozat sorszáma:** Remeha TNY 220\_1

**Termékcsoport azonosítója:** GAS 220 ACE

**Terméktípus azonosítója:** 160, 200, 250, 300

**Termék rendeltetése:** Kondenzációs állókazán

**Gyártó neve és címe:** Remeha B.V. NL, Appeldoorn Hollandia

**Gyártó képvisellete és címe:** Marketbau – Remeha Kft. 2040 Budaörs, Gyár u. 2.

A termékek teljesítmény állandóságának értékelése a 305/2011/EU rendelet szerint „+1” rendszer szerint történik.

A Marketbau-Remeha Kft. kijelenti, hogy az általa forgalomba hozott gázkészülékek megfelelnek az 2009/142/EEC és 92/42/EC hatályos előírásainak és rendelkeznek a következő engedélyekkel és tanúsítványokkal:


- CE tanúsítvány:  
CE-0063CQ3781  
(2016.09.27. Kiwa Nederland B.V. Wilmersdorf 50, 7300 AC Apeldoorn, Hollandia)

Termékekre vonatkozó teljesítmény adatok:

Alapvető tulajdonságok		Mértékegység	Típus				Műszaki előírás
			160	200	250	300	
Névleges teljesítmény (Pn) (80°/60°)	min.	kW	31,5	39,4	49,2	59,0	2009/142/EEC, 92/42/EC
	max.		152,1	194,4	243,3	290,9	
Névleges teljesítmény (Pn) (50°/30°)	min.	kW	34,7	43,2	54,1	65,0	2009/142/EEC, 92/42/EC
	max.		161,1	209,8	261,0	310,7	
Bejövő gáznyomás G20 (H gáz)	min.	mbar	17	17	17	17	2009/142/EEC, 92/42/EC
	max.		25	25	25	25	
Gázfogyasztás G20 (H gáz)	min.	m <sup>3</sup> /h	3,4	4,2	5,3	6,3	2009/142/EEC, 92/42/EC
	max.		16,5	21,2	26,5	31,6	

A fent megnevezett termékek teljesítménye megfelel a táblázatban megadott teljesítmény értékeknek. Érvényes a termék forgalmazásának a befejezéséig.

Budaörs, 2017.06.06.

  
.....  
Pethő Gábor  
műszaki vezető